



Government of Andhra Pradesh
RURAL WATER SUPPLY & SANITATION DEPARTMENT
DISTRICT LEVEL WATER TESTING LABORATORY - SPSR NELLORE
NEW Z.P COMPOUND, PODALAKUR ROAD NELLORE - 524003

Report on Chemical Analysis of Water (Drinking)
General (Physico-chemical Parameters)

Received From : ITHAKA ENGLISH MEDIUM SCHOOL, KANUPARTHIPADU , NELLORE .

Details of the sample : BORE WATER

Date of Receipt : 03.03.2022

Date of issue: 03.03.2022

Sl.No.	Physico-Chemical Parameters	Units	Water Sample	As per IS (10500 - 2012)	
				Requirement (Acceptable Limit)	Permissible Limit (in the absence of alternative source)
1	Turbidity	NTU	1.1	1.0	5.0
2	pH		7.6	6.5-8.5	No relaxation
3	Electrical Conductivity	micromhos/cm	1556	-	-
4	Total Dissolved Solids	mg/lit	1011	500	2000
5	Total Alkalinity as CaCO ₃	mg/lit	324	200	600
6	Total Hardness as CaCO ₃	mg/lit	368	200	600
7	Calcium as Ca ⁺⁺	mg/lit	77	75	200
8	Magnesium as Mg ⁺⁺	mg/lit	70	30	100
9	Flouride as F ⁻	mg/lit	0.52	1.0	1.5
10	Chloride as Cl ⁻	mg/lit	317	250	1000
11	Nitrate as NO ₃ ⁻	mg/lit	25.6	45	No relaxation
12	Sulphate as SO ₄ ⁻⁻	mg/lit	115	200	400
13	Total Iron as Fe	mg/lit	0.12	0.3	1.0


Remarks : Chemically satisfactory


Principal

ITHAKA E.M. SCHOOL
KANUPARTHIPADU,

Golagamudi Road, Nellore-524004.
Affiliation No : 130406 Code : 57150




Analyzed by
Lab Chemist

2017 - 18



NELLORE MUNICIPAL CORPORATION

D & O

TRADE LICENCE CERTIFICATE

For the year 2017 - 18

Issued Under Section 521 & 622 of HMC Act 1955

Roc.No.4930/2017/F2.

Date: 28.06.2017

Trade Licence is issued to *ITHAKA ENGLISH MEDIUM SCHOOL* to carry on the Trade/Operation of *ITHAKA ENGLISH MEDIUM SCHOOL* at Kanuparthipadu, Nellore.

Licence Fee Rs:3750/-, Demand draft No:453342,05.06.2017 Paid per annual as per the schedule for Renewal Trade Licence for the financial year 2017 - 18.

The Trader shall fulfill the following conditions or the trade licence will be cancelled.

1. Exclusive container (Bin/Bucket) for strong the premises waste to be installed and Maintained.
2. Street littering to be 'avoided'.
3. Urinals and Lavatory's should be cleaned every day.
4. If any complaint received from Public this Trade Licence Certificate will be cancelled without any further noticed and prior intimation.
5. The Drinking water supplied to the Pupils should be Wholesome and Chlorinated.
6. The Commissioner or Health Officer or any Official authorized by the Commissioner or Health Officer can inspect the unit at any time as and when required.

This licence is only for TRADE PURPOSE; It does not confer any power or Permission for either temporary or permanent exemption from the provisions of any other section of HMC Act bye-laws or rules in force.

Correspondent
Ithaka E.M. School
Kanuparthipadu,
Golagamudi Road, Nellore-524004

Commissioner
Commissioner
Municipal Corporation of Nellore
Municipal Corporation of Nellore

Principal

ITHAKA E.M. SCHOOL

KANUPARTHIPADU,

Golagamudi Road, Nellore-524004.

Affiliation No : 130406 Code : 57150

22/6/17

Roc. No.4930/2017/F2

Municipal Corporation of Nellore,
Dated: 28.06.2017.


NO OBJECTION CERTIFICATE


Sub: Municipal Corporation of Nellore – Public Health Section –
NOC, Sanitary, Trade License to run or open School at
Kanuparthipadu, Nellore - Accorded – Regarding.

Ref: 1) Application of Correspondent, Kanuparthipadu Nellore.
2) Sanitary Inspector remarks issued on dated .06.2017.

This is to certify that there is **NO OBJECTION** from Public Health point of
view to open or to run **ITHAKA ENGLISH MEDIUM SCHOOL**, Kanuparthipadu,
Nellore by Correspondent subject to following conditions :-

1. It should not be source of nuisance to the others.
2. The premises should be kept clean and neat.
3. Urinals and Latrine should be cleaned every day.
4. The staff working in the unit should not possess any type communicable diseases.
5. If any complaint received from Public this **No Objection Certificate** will be cancelled without any further notice and prior intimation.
6. The Drinking water supplied to the Peoples should be Wholesome and Chlorinated.
7. The Commissioner or Health Officer or any Official authorized by the Commissioner or Health Officer can inspect the unit at any time as and when required.


Correspondent
ITHAKA E.M. School
Kanuparthipadu,
Golagamudi Road, Nellore-524 004.



Commissioner
Municipal Corporation of Nellore.
28/6/17

To

Correspondent,
ITHAKA ENGLISH MEDIUM SCHOOL,

Ravindra Prasad Educational Society, Kanuparthipadu, Nellore.

ITHAKA E.M. SCHOOL
KANUPARTHIPADU,
Golagamudi Road, Nellore-524 004.


Principal
ITHAKA E.M. SCHOOL
KANUPARTHIPADU,

-Golagamudi Road, Nellore-524004.
Affiliation No : 130406 Code : 57150

22/6/17

Roc. No.4930/2017/F2

Municipal Corporation of Nellore,
Dated: 28.06.2017.

SANITARY CERTIFICATE

Sub: Municipal Corporation of Nellore – Public Health Section –
NOC, Sanitary, Trade License to run or open School at
Kanuparthipadu, Nellore - Accorded – Regarding.

Ref: 1) Application of Correspondent, Kanuparthipadu Nellore.
2) Sanitary Inspector remarks issued on dated .06.2017.


This is to certify that the school building and premises of
ITHAKA ENGLISH MEDIUM SCHOOL situated at Kanuparthipadu Nellore. Who are
proposed to run the classes. The accommodation provided for maximum number
of peoples is properly ventilated and lighted and the premises are kept Neat and
Clean. Necessary sanitary arrangements and drinking water are provided. The
maintenance of the school is satisfactory from the sanitation point of view.

The Municipal Corporation of Nellore has right to cancel or revoke the
certificate at any time without assigning any reasons thereof if violated sanitary
provisions.


Commissioner,
Municipal Corporation of Nellore.

To
Correspondent,
ITHAKA ENGLISH MEDIUM SCHOOL,
Ravindra Bharathi Educational Society
Kanapathipadu , Nellore.

Principal
ITHAKA E.M. SCHOOL
KANUPARTHIPADU,
Golagamudi Road, Nellore-524 004. ITHAKA E.M. SCHOOL
KANUPARTHIPADU,
Golagamudi Road, Nellore-524004.
Affiliation No : 130406 Code : 57150


Correspondent
Ithaka E.M. School
Kanuparthipadu,
Golagamudi Road, Nellore-524 004.